Request for Proposals (RFP) for Abatement of Hazardous Material Questions and Answers June 14, 2022

Jackson County Jail, 116 W Cypress Street, Edna, Texas 77957

• The survey discusses white paint on exterior window seal on the 1st floor (Sample L16), but does not address the exterior window seals on the 2nd floor though the seal is similar in color. Do the 2nd floor exterior seals contain lead?

All white exterior painted window seals should be treated as lead containing. The white exterior painted window seals shall be abated (removed or encapsulated) unless clearly rotten which can only be determined on inspection.

Who is the environmental consulting and monitoring firm for the project?

The Asbestos Consulting and Air Monitoring firm is Advanced Environmental Analysis, Inc. The lead monitoring firm has not yet been selected.